



2033 Heritage Park Drive / Oklahoma City, OK 73120 / (405) 755-7272 / Fax (405) 755-2058

Polarized Light Microscopy Asbestos Analysis Report

QuanTEM Lab No. 116182	Client: Jeff
Account Number: A000	QuanTEM Laboratories, LLC
Date Received: 09/15/2004	2033 Heritage
Received By: Michelle Bailey	OKC 73120
Date Analyzed: 09/15/2004	Project: Sample Report
Analyzed By: Barbara Taylor	Project Location: 2033 Heritage Park Drive, OKC, OK
Methodology: EPA 600	Project Number: 1234.01

QuanTEM Sample ID	Client Sample ID	Composition	Color / Description	Asbestos (%)	Non-Asbestos Fiber (%)
001	FTM-1	Layered	Green Floor Tile	Asbestos Present Chrysotile 6	Cellulose <1
001a			Black Mastic	Asbestos Present Chrysotile 2	Cellulose <1
002	TSI-1	Homogeneous	White Pipe Insulation	Asbestos Present Chrysotile 20 Amosite 10	Glass Fiber 40
003	FP-1	Homogeneous	Gold Vermiculite	Asbestos Present Actinolite/Tremolite <1	NA
004	CT-1	Homogeneous	White Ceiling Texture	Asbestos Not Present	NA
005	SV-1	Homogeneous	Red Sheet Vinyl	Asbestos Present Chrysotile 30	Cellulose 10 Glass Fiber <1
006	WBS-1	Layered	White Texture	Asbestos Present Chrysotile 2	Cellulose 2
006a			White Joint Compound	Asbestos Present Chrysotile <1	Cellulose <1

QuanTEM is a NVLAP accredited TEM and PLM laboratory (Lab Code: 101959). This report relates only to the specific items tested. NVLAP accreditation applies only to AHERA analysis [40CFR Ch. 1 (1-1-87 ed.) Part 763, Appendix A to Subparts E and F]. This report may not be used to claim product endorsement by NVLAP or any other agency of the US Government. This report may not be reproduced except in full, without the written approval of the laboratory.




2033 Heritage Park Drive / Oklahoma City, OK 73120 / (405) 755-7272 / Fax (405) 755-2058

Polarized Light Microscopy Asbestos Analysis Report

QuantEM Lab No. 116182	Client: Jeff
Account Number: A000	QuantEM Laboratories, LLC
Date Received: 09/15/2004	2033 Heritage
Received By: Michelle Bailey	OKC 73120
Date Analyzed: 09/15/2004	Project: Sample Report
Analyzed By: Barbara Taylor	Project Location: 2033 Heritage Park Drive, OKC, OK
Methodology: EPA 600	Project Number: 1234.01

QuantEM Sample ID	Client Sample ID	Composition	Color / Description	Asbestos (%)	Non-Asbestos Fiber (%)
006b			White Sheetrock	Asbestos Not Present	Cellulose 10 Glass Fiber <1
007	RF-1	Homogeneous	Black Roofing Shingle	Asbestos Not Present	Glass Fiber 60
008	AS-1	Homogeneous	Gray Transite	Asbestos Present Chrysotile 30 Crocidolite 10	Cellulose 5


 Barbara Taylor, Analyst

9/15/04
 Date of Report

QuantEM is a NVLAP accredited TEM and PLM laboratory (Lab Code: 101959). This report relates only to the specific items tested. NVLAP accreditation applies only to AHERA analysis [40CFR Ch. 1 (1-1-87 ed.) Part 763, Appendix A to Subparts E and F]. This report may not be used to claim product endorsement by NVLAP or any other agency of the US Government. This report may not be reproduced except in full, without the written approval of the laboratory.

